

Requirements for “Portable cooking under a canopy”.

1. ALL cooking equipment must be listed for commercial use.
2. Must have a minimum of a one 5-pound, Type ABC fire extinguisher.
 - Additionally, any vendor cooking with grease (deep frying) is required to have a listed Class-K fire extinguisher.
3. All fire extinguishers must have a current annual inspection attached to the extinguisher.
4. Cooking appliance(s) shall be used in accordance with their listing.
5. Cooking appliance(s) must be separated a minimum of 3 feet from combustible decorative materials (curtains, table covers, etc.)
6. Cooking appliances must be separated from tents or air supported structures by a minimum of 5 feet.
7. Propane cylinders in use, or storage, shall be secured to prevent tipping; or placed on a stable flat surface.
8. The maximum allowable quantity of propane storage shall be 200-pounds. Stored propane cylinders shall be arranged in such a manner to avoid exposure to heat, including direct sunlight.
9. All valves, fittings and hoses shall be in suitable condition for use with no visible signs of excessive wear, tear or damage, and free of leaks.
10. Smoke shall not cause objectionable conditions.
11. **CANOPY:**
 - The canopy fabric must be flame resistant, and a minimum of 5 feet from appliances.
 - Must be free standing with no more than one side attached.
 - Public may not be able to gain access underneath of the canopy.
 - Must have a barrier between the public and cooking appliance(s).
 - Gas cylinders must be located at the outer edge of the canopy and a minimum of 5 feet from the cooking appliance, with the relief valve pointing away from the canopy.